



NOTES:

1. MAXIMUM TAPPING SLEEVE SHALL NOT BE GREATER THAN ½ DIAMETER OF CONNECTING MAIN.
2. MEGA LUG RESTRAINTS ON ALL MECHANICAL JOINTS.
3. SEPARATE DOMESTIC AND FIRE SERVICES SHALL BE INSTALLED FROM THE BUILDING SERVICED TO THE PUBLIC WATER MAIN.
4. THE PROPERTY OWNER IS RESPONSIBLE FOR MAINTENANCE OF THE FIRE SERVICE FROM THE BUILDING SERVICED TO THE PUBLIC WATER MAIN

NOT TO SCALE



CITY OF FRAMINGHAM
DEPARTMENT OF PUBLIC WORKS

TYPICAL FIRE SERVICE
(TAPPING SLEEVE)

DATE:
FEB. 2016

REV:
0

DETAIL NO.

W-2.1.3