



NOTE: 5'-0" MIN. COVER

NOTES:

1. CITY OF FRAMINGHAM MAY REQUIRE FLOWABLE FILL AT ITS DISCRETION.
2. FOR LOCATIONS WHERE LEDGE IS NOT ENCOUNTERED IN TRENCH, PIPE CAN LAY ON UNDISTURBED EARTH, OR ON SAND BEDDING CONSISTENT WITH AWWA GUIDELINES.
3. FOR LOCATIONS WHERE LEDGE IS ENCOUNTERED, SAND BEDDING SHALL BE MINIMUM OF 12" THICK UNDER PIPE.
4. FILL MATERIAL SHALL BE COMPACTED TO 95% PROCTOR DENSITY.

NOT TO SCALE



CITY OF FRAMINGHAM
DEPARTMENT OF PUBLIC WORKS

WATER MAIN TRENCH DETAIL

DATE:
MARCH 2011

REV:
2

DETAIL NO.

W-2.3.0