



NOTE:

1. ALL EXCAVATION, BACKFILLING AND PAVING SHALL BE IN ACCORDANCE WITH THE TOWN OF FRAMINGHAM REQUIREMENTS.
2. WATER GATE COVER SHALL HAVE A MINIMUM HEIGHT OF 3.5 INCHES AND A MINIMUM WEIGHT OF 13 POUNDS, BRAND NAME BIBBY-STE-CROIX OR EQUAL.

NOT TO SCALE



CITY OF FRAMINGHAM
DEPARTMENT OF PUBLIC WORKS

GATE VALVE

DATE:
MARCH 2017

REV:
3

DETAIL NO.
W-2.4.0