



#10 XHHW STRANDED CU. MIN. SIZE FOR
 MAX 3% VOLTAGE DROP. ALL SPLICING
 INSIDE STREET LIGHT BASE. NO SPICING
 IN HANDHOLES.



CITY OF FRAMINGHAM
 DEPARTMENT OF PUBLIC WORKS

**HANDHOLE AND
 CONDUIT DETAIL**

Not To Scale

DATE:

DETAIL NO.

REV:

E-7.5.0